

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222881
Address: 370 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, July 26, 2023

Corrective Action Required:

1	Misc	-sod -address broken water meter lid -water meter well ring and lid to be to grade Ensure 14"-18" from top of meter to well lid ring -spark rings as required at kitchen outlets. -security screws at basement patio door 2per hinge and strike plate.
---	------	---

Comments: