

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20222881  
Address: 370 NW PATCH CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Wednesday, July 26, 2023

Corrective Action Required:

1	Misc	-sod -address broken water meter lid -water meter well ring and lid to be to grade Ensure 14"-18" from top of meter to well lid ring -spark rings as required at kitchen outlets. -security screws at basement patio door 2per hinge and strike plate. -provide issued lawn irrigation permit.
---	------	--

**Comments:**