

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233098
Address: 1804 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Failed	Thursday, July 27, 2023

Corrective Action Required:

1	Miscellaneous Correction	Full perimeter erosion control including the pile of dirt on the west lot needs to be in place. No inspections shall be conducted until erosion control measures are installed 07/27/2023. KBEARD
---	-----------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: