

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213741
Address: 2170 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Friday, July 28, 2023

Corrective Action Required:

1	Misc	-Provide accessible entry gate hardware per IBC 1010.1.9.1 -Cut exterior cleanout to grade -Complete corrections for all other departments -Label pool panel -Secure raceways within 12" of boxes at pool equipment
---	------	---

****TCO EXPIRED ON 7/28/23, 10 DAY NOTICE OF VIOLATION ISSUED**

Comments: