

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231867  
Address: 2621 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Friday, July 28, 2023

Corrective Action Required:

1	Misc	-Provide full support for lvl beam at exterior wall -Have engineer address ledger attachment not per Viet Engineering letter dated May 12, 2023 -Truss plan show truss support by hangers. -Provide attic access to roof space -Flue sticking out of the wall and going through the roof-provide verification on what this is. Looks totally non-compliant.
---	------	---

**\*\*DO NOT INSULATE**

**Comments:**