

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20221047  
Address: 795 NE ALGONQUIN ST, LEES SUMMIT, MO 64064797 NE ALGONQUIN ST, LEES SUMMIT, MO  
64064793 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Alex Fischer	Failed	Monday, July 31, 2023

Corrective Action Required:

1	Misc	**PROVIDE GRAVEL AT LOT ENTRANCE
---	------	----------------------------------

UNIT 793 ONLY:

-Connect gas line to fireplace \*\*you suppose to complete connecting the gas line to the fireplace and pressure-test

\*\*OK TO ROCK 793

Corrective Action Required:

2	Misc	-Provide gravel at entrance, fix erosion control on west side
---	------	---

**Comments:**