

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20232493  
Address: 618 SW 3RD ST, Unit:D, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:               | Inspector: | Outcome: | Date:                 |
|---------------------------|------------|----------|-----------------------|
| <b>In-wall Inspection</b> | Robb Popp  | Failed   | Monday, July 31, 2023 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | -Remove sheet rock on fur out wall for inspection of electrical<br>-NM cables are not allowed above grid ceiling |
|---|------|--|

**Comments:**