

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220067
Address: 1440 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|------------|----------|-----------------------|
| Above Ceiling Inspection | Robb Popp | Failed | Monday, July 31, 2023 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Seal all firewall penetrations -Provide proper slope at vent pipe -Install all cover plates at J boxes -Install knockout covers at all openings in j boxes |
|---|------|--|

Comments: