

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232318
Address: 2768 SW 12TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Monday, July 31, 2023

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Fire block top plate of double wall at single garage bay block vertical to horizontal- Fb penetration at top plate front door- Strap top plate (short over lap of top plate at bedroom 3 closet- Fire block gaps in bedroom 2 at ceiling height change panels
---	------	---

Comments: