

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216551  
Address: 3225 SW MARY ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Wednesday, August 02, 2023

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none"><li>- Provide spindles at garage stairs</li><li>- Provide vent hood at kitchen or land wiring in closed box</li><li>- Raise water meter pit to grade with meter 14-18" from lid</li><li>- Sidewalk inspection pending</li><li>- Final grading and sod</li><li>- Provide splash pads 36" away from foundation</li><li>- Sump discharge to be 36" away from foundation</li></ul> |
|---|------|--|

Comments: