## CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## Temporary Certificate of Occupancy

Permit #: PRCOM20223476

Address: 1301 NW RIVER RD, LEES SUMMIT, MO 640811451 NW RIVER RD, LEES

SUMMIT, MO 640813151 NW VIEW HIGH PKWY, LEES SUMMIT, MO

640811401 NW RIVER RD, LEES SUMMIT, MO 64081

Inspected On: Wednesday, August 02, 2023

**Inspected By:** Mike Weisenborn

Expiration Date: 9/1/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.** 

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Mike Weisenborn Ready for Temp CO Wednesday, August

Codes Commercial 02, 2023

Corrective Action Required:

1 Miscellaneous This inspection is related the ten (10) playing fields and associated

Correction areas and currently permitted facilities.

Corrective Action Required:

2 Miscellaneous 7/11/23

Correction -Complete all electrical associated with permit

-Provide all panel schedules and labels

-Close open spaces at panels

-Open scoreboard disconnects for inspection

-Complete outstanding items from Planning, Engineering and Fire.

Corrective Action Required:

3 Miscellaneous Completed any and all outstanding items associated to the site

Correction development permit. PRSITE20201955.

Corrective Action Required:

4 Miscellaneous Complete landscaping and revegitation as indicated in previous

Correction inspections.

Corrective Action Required:

5 Miscellaneous Completion of the interconnect water meter between Lee's

Correction Summit and KDMO public water systems.