CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #:	PRCOM20223476
Address:	1301 NW RIVER RD, LEES SUMMIT, MO 640811451 NW RIVER RD, LEES
	SUMMIT, MO 640813151 NW VIEW HIGH PKWY, LEES SUMMIT, MO
	640811401 NW RIVER RD, LEES SUMMIT, MO 64081
Inspected On:	Wednesday, August 02, 2023
Inspected By:	Mike Weisenborn
Expiration Date:	9/1/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mike Weisenborn	Ready for Temp CO	Wednesday, August 02, 2023

Corrective Action Required:

1MiscellaneousThis inspection is related the ten (10) playing fields and associated
areas and currently permitted facilites.

Corrective Action Required:

2 Miscellaneous 7/11/23

Correction -Complete all electrical associated with permit

- -Provide all panel schedules and labels
- -Close open spaces at panels
- -Open scoreboard disconnects for inspection
- -Complete outstanding items from Planning, Engineering and Fire.

Corrective Action Required:

3 Miscellaneous Completed any and all outstanding items associated to the site

Correction development permit. PRSITE20201955.

- Corrective Action Required:
- 4 Miscellaneous Complete landscaping and revegitation as indicated in previous Correction inspections.

Corrective Action Required:

5MiscellaneousCompletion of the interconnect water meter between Lee's
Summit and KDMO public water systems.