

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221207
Address: 3525 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Thursday, August 03, 2023

Corrective Action Required:

1	Miscellaneous Correction	- Top plate in garage needs to be fire blocked. South wall - Bedroom 3 needs nail plate for electrical S/W corner - bathroom in bedroom 1 needs fire blocking at top plate above vanity
---	--------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: