

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215211

Address: 4023 NE SAGAMORE DR, LEES SUMMIT, MO 64064
4025 NE SAGAMORE DR, LEES SUMMIT, MO 64064
4027 NE SAGAMORE DR, LEES SUMMIT, MO 64064
4021 NE SAGAMORE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Shawn Hoffman	Failed	Thursday, August 03, 2023

Corrective Action Required:

1	DCM5 ESC INSP DENIED	REQUESTED INSPECTION(S) DENIED DUE TO DEFICIENT EROSION CONTROL INSTALLATION.
---	-------------------------	--

****PROVIDE EROSION CONTROL ALONG THE STREET. BOTTOM OF THE SILT
FENCE SHALL BE BURIED MIN 6" BELOW SOIL**

****CLEAN STORM INLET**

Comments: