

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215211

Address: 4023 NE SAGAMORE DR, LEES SUMMIT, MO 640644025 NE SAGAMORE DR, LEES SUMMIT, MO
640644027 NE SAGAMORE DR, LEES SUMMIT, MO 640644021 NE SAGAMORE DR,
LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Shawn Hoffman	Failed	Thursday, August 03, 2023

Informational:

1	Misc	Attic 2-hr firewall-2nd layer ok
---	------	----------------------------------

****provide fire protection under roof decking**

Corrective Action Required:

2	MISC	- NO ACCESS - NO ANSWER TO CALL WAS ABLE TO GET IN 4033 BUT NO PLANS ON SIGHT.
---	------	--

Comments: