

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215211

Address: 4023 NE SAGAMORE DR, LEES SUMMIT, MO 64064
4025 NE SAGAMORE DR, LEES SUMMIT, MO 64064
4027 NE SAGAMORE DR, LEES SUMMIT, MO 64064
4021 NE SAGAMORE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, August 03, 2023

Corrective Action Required:

1 Misc

Garage portal wall inspection only:
-Nail sheathing to double studs @3" oc
-Nail sheathing to LVL with 3" grid pattern
-Nail to sill plate @ 3" oc

Corrective Action Required:

2 Misc

- NO ACCESS
- NO ANSWER TO CALL
WAS ABLE TO GET IN 4033 BUT NO PLANS ON SIGHT.

Comments: