

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213592

Address: 3722 SW WALSH DR, LEES SUMMIT, MO 640823724 SW WALSH DR, LEES SUMMIT, MO 640823726
SW WALSH DR, LEES SUMMIT, MO 640823720 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Thursday, August 03, 2023

Corrective Action Required:

1	Miscellaneous Correction	3726
---	--------------------------	------

- Basement a/c supply line needs a hanger installed (line is over 10 ft)
- Joist hanger behind furnace in not installed correctly, nails were installed at a angle and do not serve it intended purpose

Not a complete list , all trades were not completed at the time of inspection

Corrective Action Required:

2	Misc	3726
---	------	------

- Basement a/c supply line needs a hanger (it is over 10 feet in length)
- Joist hanger behind furnace in not installed correctly, nails were installed at an angle and does not serve its intended purpose

3724

- Address all trusses that have been scabbed onto along the webbing and bottom cord
- Radon is not completely installed

This is a partial list, units 3722 and 3720 will be scheduled at a later date
08/03/2023 KBEARD

Comments: