

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231510  
Address: 362 NW PATCH CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, August 03, 2023

Corrective Action Required:

1	Misc	Underground gas pipe depth okay Okay to cover
		Provide minimum 10psi at pressure gauges (current gauge is faulty) Paint gas line at equipment slab

**Comments:**