

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20223368  
Address: 2911 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Nick Scott	Passed	Thursday, August 03, 2023

**Corrective Action Required:**

1	Misc	6-8-23 NS Site visited Sidewalk ramp did not pass ADA. There is no 5 foot turn around for a person that is in a wheel chair. This will need to be tore out and replaced to meet ADA standards. Please call me Nick Scott at 816-977-5652 to meet up and I can explain what needs to change. 8-3-23 NS Site visited and it appears that sidewalk meets city standards ADA passed.
---	------	---

**Comments:**