

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20216551  
**Address:** 3225 SW MARY ST, LEES SUMMIT, MO 64081  
**Inspected On:** Thursday, August 03, 2023  
**Inspected By:** Shawn Hoffman  
**Expiration Date:** 9/2/2023 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Pending	

**Corrective Action Required:**

- |   |      |  |
|---|------|--|
| 1 | Misc | - Raise water meter pit to grade with meter 14-18" from lid<br>- Sidewalk inspection pending<br>- Final grading and sod<br>- Provide splash pads 36" away from foundation<br>- Sump discharge to be 36" away from foundation |
|---|------|--|