

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222877
Address: 2105 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Devon Perry	Partial	Thursday, August 03, 2023

Informational:

1	Misc	7-19-23 DP. SW was formed, aggregate compacted. Cross slopes were a little wishy washy. Contractor went through with me and got the slopes in compliance. But conditions can change. Approved to pour.
		8-3-23 DP. SW on side of house not connected to existing SW. Can't pass until finished.

Comments: