

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230879
Address: 699 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Thursday, August 03, 2023

Corrective Action Required:

1	Misc	-Complete all directional marking for drive though -Complete landscaping -Provide ASSE 1022 or 1024 backflow devices at coffee machines -Provide fire extinguisher at kitchen -Install missing sprinkler escutcheon at restroom corridor -Receptacles in bar area to be GFCI protected -Provide panel schedules -Obtain Jackson County Health Department approval
---	------	--

Comments: