

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213592

Address: 3722 SW WALSH DR, LEES SUMMIT, MO 640823724 SW WALSH DR, LEES SUMMIT, MO 640823726
SW WALSH DR, LEES SUMMIT, MO 640823720 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Friday, August 04, 2023

Corrective Action Required:

3	Miscellaneous Correction	3726 still needs a support hanger in the basement for the a/c supply vent line that is over 10 feet in length. This is the third time this has been noted on an all rough.
---	--------------------------	--

Okay to insulate and sheet rock since basement is unfinished. This is a partial pass only. 3720 and 3722 will be inspected at a later date 08/04/2023. KBEARD time 9:45AM

Comments: