CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231857

Address: 4809 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Alex Fischer Failed Friday, August 04, 2023

Residential

Informational:

1 MISC FRAMING OF THE GARAGE PORTAL AND REAR CSPF WALLS-OK

Informational:

2 Misc Note: the plans jump from bedroom 2 to bedroom 4 then 5. Plans do not

show bedroom 3.

Corrective Action Required:

3 Misc -Missing fire blocking at top plate at wall between laundry and pantry

-Needs more nails in exterior corner 2x4's

-Missing fire blocking at top plate to the left of shower entrance

-Missing fire blocking at top plate near right side of entrance to bedroom 2

-Missing vent to the exterior in basement bathroom

Comments: