

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20232941  
Address: 2626 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Residential</b>	Mitchell Schwarz	Failed	Monday, August 07, 2023

Corrective Action Required:

1	Misc	Perimeter bond. When using copper, must be 18"-24" from inside wall of pool. And 4"-6" deep below sub grade.
---	------	--

**Comments:**