

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231510
Address: 362 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	Robb Popp	Partial	Tuesday, August 08, 2023

Corrective Action Required:

1	Misc	Underground gas pipe depth okay Okay to cover
---	------	--

*PAINT EXTERIOR METALLIC GAS LINES WITH CORROSION RESISTANT PAINT

Comments: