

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213592

Address: 3722 SW WALSH DR, LEES SUMMIT, MO 640823724 SW WALSH DR, LEES SUMMIT, MO 640823726  
SW WALSH DR, LEES SUMMIT, MO 640823720 SW WALSH DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Kyle Beard	Failed	Tuesday, August 08, 2023

Informational:

1	Miscellaneous Correction	3726 and 3724 passed only. This is a partial pass only
---	--------------------------	--

Corrective Action Required:

2	Miscellaneous Correction	Gas gauge at 3722 read 2 lbs upon arrival and does not have enough pressure for a proper inspection
---	--------------------------	---

3720 passed

**Comments:**