



PROJECT NAME LEOK Office Renovation – Tenant Improvement Package
CLIENT NAME Leigh + O’Kane
PROJECT NO. 23033
PERMIT NO. PRCOM20233498
Date: August 08, 2023

General Information Drawings:

G000:

- a. Updated Sheet Index.

G003:

- a. Updated Code information.
- b. Updated FE-1 description in Fire Resistive Legend.

Structural Drawings:

S01:

- a. Revised snow loads per 2018 IBC 1608.2.

Architectural Drawings:

A101:

- a. Revised storefront and door to Conference Room 112.
- b. Revised Lobby feature wall to accommodate new door 112 clearance requirements.
- c. Revised Lobby furnishings to remove shuffleboard table and replace with freestanding dining table with accessible seating area.
- d. Added dimensions and section details to island counter.

A501:

- a. Revised door types D3 and D4.
- b. Updated Doors 105, 106, 108 to be 7'H. Updated door 112 to type D4.
- c. Revised window type W2.
- d. Revised Finish Legend for HW2 and HW3.
- e. Added section and elevation details of island counter.

A712:

- a. Added Appliance Legend. Updated appliances.
- b. Revised Lobby feature wall width (H12).
- c. Revised storefront and door 112 at Conference Room 112 (H8).
- d. Revised island counter appliances; added section details (H2).
- e. Revised kitchenette appliances and countertop height (D12).



A713:

- a. Revised storefront and door 112 at Conference Room 112 (H4).
- b. Revised countertop height; added adjustable shelving at upper cabinets (A7).

Mechanical Drawings:

M101:

- a. Shifted RTU-1 to maintain 10' clearance from building parapet.
- b. Added plan note #6 to clarify outside air intake location.

Plumbing Drawings:

P000:

- a. Removed Fire Protection General Notes.

P101:

- a. Revised natural gas piping to reflect updated RTU-1 location.

Electrical Drawings:

E101:

- a. Shifted location of RTU-1 to match mechanical drawings.

E102:

- a. Updated light fixture H.

End of Revisions