

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20233601  
Address: 2121 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Wednesday, August 09, 2023

Corrective Action Required:

1	Misc	-Fireblock walls at all furdow ceilings -Seal gaps in furout wall fireblocking at panel and closet -Provide midpoint strap at 2" dwv to prevent lateral movement
---	------	--

**Comments:**