

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226005
Address: 1901 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Mitchell Schwarz	Failed	Wednesday, August 09, 2023

Corrective Action Required:

1	Misc	Provide minimum 5psi or 10' water column for inspection.
		No pressure at gauge at time of inspection 8/9/23 11:00AM

Comments: