

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20213746
Address: 725 SW 15TH CIR, LEES SUMMIT, MO 64081
Inspected On: Wednesday, August 09, 2023
Inspected By: Alex Fischer
Expiration Date: 9/8/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Pending	

Corrective Action Required:

1	Misc	4/18-TCO approved MUST HAVE SOD INSTALLED 10 FEET FROM HOUSE After sod installation we need to perform a site inspection. -final grade and sod -check water meter depth and grade at time of final sod and grade meter to be 14"-18" from meter top to well lid. close shopw permit also
---	------	--

Corrective Action Required:

2	Misc	-Erosion control failed in back yard
---	------	--------------------------------------

Corrective Action Required:

3	MISC	TCO extension form granted Alex Fischer 08/08/2023 7:22 AM
---	------	---

