

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20223227  
Address: 1028 SW ARMIE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Thursday, August 10, 2023

Corrective Action Required:

- |   |      |   |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none"><li>- sidewalk inspection pending</li><li>- Final grading and sod</li><li>- Provide splash pads 26" away from foundation</li><li>- Seal all exterior penetrations</li><li>- Seal top of electrical meter can and A/C disconnect</li><li>- Sump discharge shall be 36" away from foundation</li><li>- Paint gas exterior piping</li><li>- Provide anti siphon device on spigot at water main</li></ul> |
|---|------|---|

Comments: