

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20222104  
Address: 1608 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Thursday, August 10, 2023

Corrective Action Required:

1 Misc

- Address pending driveway inspection
- Provide as graded plot plan
- secure A/c whip within 12" of disconnect
- splash blocks to extend 36" from foundation
- identify sewer tracer wire.
- address deck post to beam connections and deck post to be continuous per plans.

**Comments:**