

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20225303  
Address: 901 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Friday, August 11, 2023

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>-Complete corrections for all other departments</li><li>-Provide panel labels and schedules</li><li>-Install permanent electrical panel equipment-close all holes in panels</li><li>-Provide permanent signage throughout</li><li>-Complete electrical at break room</li><li>-Install all wood panels and ensure boxes are flush with face of combustible materials</li><li>-Label RTUs</li><li>-Drinking fountain requires min 27" knee clearance with top 30' to 34"</li><li>-Provide accessible restroom signage at latch side of door</li><li>-Cut exterior cleanouts to grade</li><li>**OK to bring in and set up equipment</li></ul>
---	------	--

**Comments:**