CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20232458Address:2818 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Friday, August 11, 2023
Corrective Action Required:			
1 Misc	 -Support PVC plumbing at max 10 ft vertical -Support electrical box per code; support MC to independent support wire, color tag, and secure support wire at bottom end. Use listed support clips for MC support -Color/ ID all support wires for MC -Do not use ceiling grid support wire to support MC -Support low voltage cables off ceiling grid in a nice&workmanlike manner 		

Comments: