

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215800
Address: 1600 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, August 14, 2023

Corrective Action Required:

1 Misc

- Security-block rear exterior door at strike plate height per code
- Fb front basement bedroom wall at I beam web
- Securely fasten wiring to framing @ max 4.5 ft interval, not just laying them loosely onto soffit framing
- Brace interior walls per plan and code on correct side

****OK TO INSULATE**

Comments: