

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221047
Address: 795 NE ALGONQUIN ST, LEES SUMMIT, MO 64064 797 NE ALGONQUIN ST, LEES SUMMIT, MO 64064 793 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Tuesday, August 15, 2023

Partial Correction:

1 Misc

****PROVIDE GRAVEL AT LOT ENTRANCE**

Corrective Action Required:

2 Miscellaneous
Correction

795

- Install truss hanger above front entry bathroom
- Gas line to fireplace is not connected
- Gas line in basement is not bonded

797

- Gas line to fireplace is not connected
- Fire rated assembly is not vertically blocked off every 10 feet on center
- Install truss hanger above front entry bathroom
- Fb basement wall space from soffit

****OK TO INSULATE**

Comments: