

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221047

Address: 795 NE ALGONQUIN ST, LEES SUMMIT, MO 64064
797 NE ALGONQUIN ST, LEES SUMMIT, MO 64064
64064793 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|--------------|----------|--------------------------|
| Rated Assembly Inspection | Khanh Nguyen | Failed | Tuesday, August 15, 2023 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -Cover all excessive gap between FlameBlock sheathings at ridge above units 795 |
|---|------|---|

Comments: