

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20233779  
Address: 3542 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Kyle Beard	Failed	Wednesday, August 16, 2023

Corrective Action Required:

- |   |                          |   |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none"><li>- Top plate penetrations need to be fire blocked</li><li>- Toilet does not have waterline ran to it</li><li>- Toilet flange is not installed</li><li>- Main water supply line at top plate needs a nail plate installed</li></ul> |
|---|--------------------------|---|

Comments: