

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231716

Address: 2012 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822014 SW HOLDBROOKS DR, LEES SUMMIT,
MO 640822016 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822018 SW HOLDBROOKS
DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Wednesday, August 16, 2023

Corrective Action Required:

1	Miscellaneous Correction	2016 - CSPF straps missing on back wall
		2014 - CSPF straps missing on back wall
		2012 - CSPF straps missing on back wall - One CSPF strap missing in garage

Comments: