

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231176

Address: 2127 SW OSAGE DR, LEES SUMMIT, MO 640822129 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Thursday, August 17, 2023

Corrective Action Required:

1	Miscellaneous Correction	2129 - sump pump extension is not connected - West side of property drainage does not correspond with the approved plot plan - Front driveway west side has lots of erosion under it and needs to be addressed
		2127 - driveway east side has erosion under it and needs to be addressed

Comments: