

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231105  
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	John Jackson	Partial	Thursday, August 17, 2023

Informational:  
1 Misc 08/17/23 Thursday JMJ (ESS)  
Contractor vacuum tested MH. MH-1, MH-3, MH-5 passed vacuum test. MH-2 & MH-4 failed the the vacuum test.

**Comments:**