

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20221409  
Address: 2022 SW RED BARN LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Thursday, August 17, 2023

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- label non Gfci outlets</li><li>- Add a GFCI protected outlet at sump</li><li>- Provide security screws on exterior doors (2) per hing</li><li>- Provide (2)2 1/2" through bolts at post to beam connections</li><li>- Paint exterior gas piping</li><li>- Provide shut off at gas piping at fire pit</li><li>- Land sewer trace wire to grade</li><li>- Will inspect laundry room on next one , painting now</li><li>- Obtain an irrigation permit and submit a back flow certificate</li></ul>
---	------	---

**Comments:**