

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231513  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Failed	Friday, August 18, 2023

Corrective Action Required:

1	Misc	-Secure all electrical within 12" of boxes -Support all LV off of grid -Seal gaps and penetrations at smoke walls -Label smoke walls -Cover all Open holes in j boxes -Remove tile for inspection
---	------	--

**Comments:**