

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231589

Address: 2135 SW OSAGE DR, LEES SUMMIT, MO 640822133 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|-----------|-------------------------|
| Occupancy Inspection - Codes Residential | Kyle Beard | Not Ready | Monday, August 21, 2023 |

Corrective Action Required:

| | | |
|---|--------------------------|------|
| 1 | Miscellaneous Correction | 2135 |
|---|--------------------------|------|

- Kitchen faucet not installed
- Kitchen backsplash electrical outlet not installed
- Garage to house door is missing hardware to close
- Back patio flood light not installed
- Master bathroom shower is not completed

This is not a complete list. This duplex is not ready for an occupancy inspection and should have not been scheduled. Walk your property and make sure it is ready before scheduling an inspection!
08/21/2023 KBEARD 8:20AM

Comments: