

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	John Jackson	Partial	Monday, August 21, 2023

Informational:
1 Misc

08/17/23 Thursday JMJ (ESS)
Contractor vacuum tested MH. MH-1, MH-3, MH-5 passed vacuum test. MH-2 & MH-4 failed the the vacuum test.

08/21/23 Monday JMJ (ESS)
MH-2 & MH-4 passed vacuum test completing test on public sanitary main.

Comments: