

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221052
Address: 3206 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Bobby Richest	Passed	Monday, August 21, 2023

Informational:

1 Misc

7-27-23 BR Sidewalk is framed and ready for concrete.

8-9-23 BR Sidewalk panels is not compliance with LS specifications for sidewalks. LS specification for sidewalks panels are 5x5 which these panels aren't they are serveral panels that is 5x6.

8-21-23 BR Sidewalk panels are fix up to LS specification.

Comments: