

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232493
Address: 618 SW 3RD ST, Unit:D, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Failed	Tuesday, August 22, 2023

Corrective Action Required:

1 Misc

8/22/23

****NO ACCESS, INSPECTION NOT PERFORMED. CONTRACTOR TO BE ON SITE OR PROVIDE ACCESS**

-Observed from outside: Complete electrical at exit device, support all lights with dedicated wires at (2) opposite corners, support and secure all MC and LV off of grid.

Comments: