

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20224767  
Address: 1100 NW MAIN ST, Unit:D, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Partial	Tuesday, August 22, 2023

Corrective Action Required:

1	Misc	Demising wall screw pattern: -West side complete -East side complete **Seal perimeter and all penetrations  Riser room screw pattern complete **Seal perimeter and all penetrations
---	------	---

**Comments:**