## LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1303
FAX (816) 969-1313
TDD (816) 969-7407

## PLANS REVIEW CONDITIONS

Permit No: PRCOM20110420 Date: July 05, 2011

Project Title: CRAZY 8 Applicant: Location: 910 NW BLUE PKWY. Unit:P KCFS

LEES SUMMIT, MO 64086 901 E. Loula

Type of Work: Alarm Alteration Olathe, KS 66061 Occupancy Group: M (913) 720-5237

Description: TENANT FINISH FOR

CHILDRENS CLOTHING STORE

Construction Type: Type IIB (Unprotected)

Map Page: 195A

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review Reviewed By: Jim Eden Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans received June 16, 2011.

2. Duct detection alarms shall be supervisory only without activating the interior alarm notification appliances.

Verified at inspection.

3. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action required: Call (816) 969-1300 to schedule alarm test.